



Job #15585753

Air Conditioning Tune Up Report

Job Info	
Date 6/6/2018	Technician Name Shawn Wiebke
Customer Rasmussen, Evan	Location Address 2021 Market Street, La Crosse, WI 54601 USA
Phone (608) 354-7706	Contact Person -
Model Number (1) EL16XC1-024-230A01	Serial Number (1) 5915K2501
Model Number (2) -	Serial Number (2) -
Air Filter Type & Size (1) 16x25x1	Air Filter Type & Size (2) -
Checklist	
1. Check Thermostat and adjust where necessary <input checked="" type="checkbox"/> OK	2. Ensure all electrical connections are tight <input checked="" type="checkbox"/> OK
3. Inspect low and high voltage wiring <input checked="" type="checkbox"/> OK	4. Oil condenser fan motor <input checked="" type="checkbox"/> OK
5. Test safety controls <input checked="" type="checkbox"/> OK	6. Clean condensate drains <input checked="" type="checkbox"/> OK
7. Clean debris out of outdoor condenser unit <input checked="" type="checkbox"/> OK	8. Check refrigerant level and advise leak detection if necessary <input checked="" type="checkbox"/> OK "No leaks detected."
9. Clean and adjust blower components <input checked="" type="checkbox"/> OK	10. Measure indoor evaporator temperature drop 21
11. Inspect and adjust belts <input checked="" type="checkbox"/> N/A	12. Adjust humidifier damper <input checked="" type="checkbox"/> N/A

13. Measure evaporator super heat 10	14. Tighten all refrigerant valve caps <input checked="" type="checkbox"/> OK
15. Inspect and clean air filter, replace with customer consent if necessary <input checked="" type="checkbox"/> Needs Action "More frequent filter changes recommended"	16. Reseal outside line set penetration if necessary <input checked="" type="checkbox"/> OK
17. Additional notes Overall, system is in good working order. Continue to maintain on an annual basis	

Signature/Initials

Technician

SW

Customer

ER