



Job #15585753

Gas Boiler Tune Up Report

Job Info	
Date 1/10/2019	Technician Name Shawn Wiebke
Customer Rasmussen, Evan	Phone (608) 354-7706
Location Address 2021 Market Street, La Crosse, WI 54601 USA	Contact Person -
Model Number (1) ECO 110	Serial Number (1) 5812K25033
Model Number (2) -	Serial Number (2) -
Checklist	
1. Check thermostat and make adjustments where necessary <input checked="" type="checkbox"/> OK	2. Drain expansion tank if unit has isolation valves <input checked="" type="checkbox"/> OK
3. Test flue damper operation <input checked="" type="checkbox"/> OK	4. Check / adjust temperature and pressure settings <input checked="" type="checkbox"/> OK
5. Test safety controls <input checked="" type="checkbox"/> OK	6. Remove rust and soot and clean and adjust burners and heat exchanger <input checked="" type="checkbox"/> OK
7. Clean and adjust ignition assembly or OHM ignitor <input checked="" type="checkbox"/> OK	8. Check micro amperage signal from flame sensor <input checked="" type="checkbox"/> OK
9. Adjust gas / air mixture for optimum efficiency <input checked="" type="checkbox"/> OK	10. Oil motor bearings <input checked="" type="checkbox"/> OK
11. Check and tighten all exhaust pipe connections <input checked="" type="checkbox"/> OK	12. Clean condensate trap if high efficiency boiler <input checked="" type="checkbox"/> OK
13. Perform combustion tests (See levels below) <input checked="" type="checkbox"/> OK	14a. Level of CO (carbon monoxide) 15ppm
14b. Level of O2 4%	14c. Level of Efficiency 95%

15. Check all gas connections located in unit <input checked="" type="checkbox"/> OK	16. Adjust gas / pilot pressure <input checked="" type="checkbox"/> OK
17. Inspect and clean heat exchanger thoroughly <input checked="" type="checkbox"/> OK	18. Check electrical wiring and tighten all electrical connections <input checked="" type="checkbox"/> OK
19. Cycle unit and make adjustments accordingly <input checked="" type="checkbox"/> OK	20. Additional notes Unit is in good working order, continue to maintain on an annual basis

Signature/Initial

Customer

ER

Technician

SW